



PSB Singapore

# TEST CERTIFICATE

This Certificate is issued to

Albert Hoo Electrical Pte Ltd  
24 Kaki Bukit View  
Singapore 415960

## FOR

Product: Steel Surface Cable Trunking and Accessories

Brand/Model: KRIPAL / -

## Detail:

Size (mm)	Thickness of Body Materials (mm)	Thickness of Cover Materials (mm)
50 (W) X 50 (H)	1.0	1.0
100 (W) X 50 (H)	1.2	1.2
100 (W) X 75 (H)	1.2	1.2
150 (W) X 100 (H)	1.4	1.2

Classification: Class 1

Colour: Orange

Specification: SS 249 : 1981 (2012)

Test Report: a) 7191110201-EEC15/01-SYG  
b) 7191110201-CHM15/02-PGK(EEC)

Date of Test Report : a) 04 May 2015  
b) 27 Apr 2015

## Summary

A sample of the product has been tested and is found to meet with the requirements of the above specification.

TÜV SÜD PSB Pte Ltd

Certificate No:  
03460

Date of Original Issue:  
01/07/2015

Date of Last Revision:  
30/06/2017

Date of Expiry:  
30/06/2019

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Test Certification Scheme.

Note: This Certificate is issued pursuant to the terms set out overleaf.