

EC CERTIFICATE OF CONFORMITY

0470 - CPD - 0031

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

Input/Output Devices with Short Circuit Isolator

Product	Brand	Type
Dual Monitored Input/Output Unit	Autronica	BN-305
Monitored Fire Alarm Device Control Unit	Autronica	BN-307
Conventional Loop Interface	Autronica	BNB-331

placed on the market by and produced in the factory of:

AUTRONICA Fire and Security AS
Haakon VII's gate 4
NO-7483 Trondheim, Norway

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the Notified Body No. 0470 – Nemko AS - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standards

EN 54-17:2005
EN 54-18:2005

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 22. December 2011 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Oslo, 22.12.2011

Notified Body Id. no. 0470
Nemko AS
P.O. Box 73 Blindern
NO-0314 OSLO



Geir Hørthe
Nemko AS