

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **Optical smoke and heat detector AUTRONICA BHH-320 with integrated short-circuit isolator**

The product fulfils the essential characteristic:

**See Annex 1**

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:  
**Autronica Fire and Security AS**  
**Bromstadvegen 59**  
**NO-7047 Trondheim**  
**Norway**

and produced in the manufacturing plant:  
**CPA10058**

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

**EN 54-5:2017/A1:2018** : **Fire detection and fire alarm systems - Part 5: Heat detectors - point heat detectors**  
**EN 54-7:2018** : **Fire detection and fire alarm systems - part 7: Smoke detectors - Point smoke detectors that operate using scattered light, transmitted light or ionization**  
**EN 54-17:2005** : **Fire detection and fire alarm systems - Part 17: Short-circuit isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### **CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.**

This certificate was first issued on 2022-08-09 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2022-08-09**.



Merete Poulsen  
Responsible for evaluation



Steen Nilsson  
Responsible for certification decision

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S**

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)



**DANAK**  
Prod. Reg. Nr. 7023

Version 2022-02-08  
Page **1** of **10**

Annex 1

EXTENT

**Model Reference:**

Optical smoke and heat detector AUTRONICA BHH-320 with integrated short-circuit isolator.

Kit BH-XXX = BHH-XXX and BWA-100

**Variants:**

Optical Smoke and Heat detector		
Brand	Type	Class (Heat)
Autronica	BHH-220	A1
Autronica	BHH-520	A1
Autronica	BHH-520/N	A1
Autronica	BHH-520/EX	A1

**Base:**

BWA-100 (Conventional)

**Operating Voltage:**

10 to 27 V DC

**Heat Response Category:**

**Table 1**

Detector Category (Heat Class):	Typical Application Temperature	Maximum Application Temperature °C	Minimum Static Response Temperature °C	Maximum Static Response Temperature °C
A1	25	50	54	65

**Table 2- Response time limits**

Rate of rise of air temperature K min <sup>-1</sup>	Cat A1			
	Lower limit		Uper limit	
	Min	S	Min	S
1	29	0	40	20
3	7	13	13	40
5	4	9	8	20
10	1	0	4	20
20		30	2	20
30		20	1	40

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

Performance				
Essential characteristics	Clauses in EN 54-5:2017/ A1:2018	Regulatory classes	Performance	
<b>Operational reliability:</b>				
Position of heat sensitive element	4.2.1	A1	The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g. characteristic correctors), are a distance $\geq 15$ mm from the mounting surface of the point heat detector.	
Individual alarm indication	4.2.2		Category A1 The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector, in an ambient light intensity up to 500 lx.	
Connection of ancillary devices	4.2.3		Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector	
Monitoring of detachable point heat detectors	4.2.4		A fault condition is signaled when the detector is removed from the mounting base.	
Manufacturer's adjustments	4.2.5		It is not possible to change the manufacturer's settings except by special means (e.g. a special code or tool, or by breaking or remove a seal).	
Onsite adjustments of response behavior	4.2.6		N/A	
Software controlled detectors	4.2.7		The software documentation and the software design complies supplied by the manufacturer with the requirements of this standard.	
<b>Nominal activation conditions/Sensitivity:</b>				
Directional dependence	4.3.1		The response time of the point detector do not unduly depend on the direction of airflow around the point heat detector.	
Static response temperature	4.3.2		The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above.	
Response times from typical application temperature	4.3.3		The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above.	
Response times from 25 °C	4.3.4		The response time at 3 K min <sup>-1</sup> exceeds 7 min 13 s and the response time at 20 K min <sup>-1</sup> exceeds 1 min 0 s.	
Response times from high ambient temperature	4.3.5		No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temperatures.	
A1				

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

			3 K min <sup>-1</sup> , Lower limit, 1 min 20 s and upper limit 13 m 40 s. 20 K min <sup>-1</sup> , Lower limit, 12 s and upper limit 2 m 20 s.												
Reproducibility	4.3.6		The response times of the point heat detectors lie between the lower and upper response time limits specified in Table 2 above.												
<b>Response delay (response time):</b>															
Additional test for suffix S point heat detectors	4.4.1		N/A												
Additional test for suffix R point heat detectors	4.4.2		N/A												
<b>Tolerance to supply voltage:</b>															
Variation in supply parameters	4.5		The point heat detector does not unduly depend on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above.												
<b>Durability of nominal activation conditions/Sensitivity:</b>															
temperature resistance															
Cold (operational)	4.6.1.1		No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the conditioning temperature  Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.  <u>A1</u> : 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6												
Dry heat (endurance)	4.6.1.2		No fault signal was given on reconnection attributable to the endurance conditioning  <table border="1"> <thead> <tr> <th>Point heat detector category</th> <th>Conditioning Temperature °C</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>80 ±2</td> </tr> <tr> <td>D</td> <td>95 ±2</td> </tr> <tr> <td>E</td> <td>110 ±2</td> </tr> <tr> <td>F</td> <td>125 ±2</td> </tr> <tr> <td>G</td> <td>140 ±2</td> </tr> </tbody> </table> Response time at 3 K min <sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.  <u>A1</u> : 20 K min <sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6	Point heat detector category	Conditioning Temperature °C	C	80 ±2	D	95 ±2	E	110 ±2	F	125 ±2	G	140 ±2
Point heat detector category	Conditioning Temperature °C														
C	80 ±2														
D	95 ±2														
E	110 ±2														
F	125 ±2														
G	140 ±2														
Humidity resistance															
Damp heat, cyclic (operational)	4.6.2.1		No alarm or fault signal was given during the conditioning.												

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

		<p>Lower temperature: (25±3) °C Upper temperature: (40±2) °C</p> <p>Relative humidity: At lower temperature :≥ 95 % At upper temperature : (93 ±3) %</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Damp heat, steady-state (endurance)	4.6.2.2	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 40 ±2 °C Relative Humidity: 93 ±3 % Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Corrosion resistance		
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.6.3	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning Temperature : 25 ±2 °C Relative Humidity: 93 ±3 % SO<sub>2</sub> concentration: 25 ±5 ppm (by volume) Duration : 21 days</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration resistance		
Shock (operational)	4.6.4.1	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>For specimen with a mass ≤ 4,75 kg :</p> <p>Shock pulse type: Half sine Pulse duration : 6 ms Peak acceleration: 10X (100-20M) ms<sup>-2</sup> (M is specimen mass in Kg) Number of directions: 6</p>

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

		<p>Pulses per direction: 3</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Impact (operational)	4.6.4.2	<p>No alarm or fault signal was given during the conditioning period or an additional 2 min.</p> <p>Conditioning:                      Impact energy: 1,9 ±0,1 J                      Hammer velocity: 1,5 ±0,13 ms<sup>-1</sup>                      Number of impacts: 1</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (operational)	4.6.4.3	<p>No fault signal was given during the conditioning</p> <p>Conditioning:                      Frequency range: 10 to 150 Hz                      Acceleration amplitude: 5 ms<sup>-2</sup>(≈0,5 g<sub>n</sub>)                      Number of axes : 3                      Sweep rate: 1 octave min<sup>-1</sup>                      Number of sweep cycles: 1 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Vibration, sinusoidal (endurance)	4.6.4.4	<p>No fault signal was given on reconnection attributable to the endurance conditioning.</p> <p>Conditioning:                      Frequency range: 10 to 150 Hz                      Acceleration amplitude: 10 ms<sup>-2</sup>(≈1,0 g<sub>n</sub>)                      Number of axes : 3                      Sweep rate: 1 octave min<sup>-1</sup>                      Number of sweep cycles: 20 per axis</p> <p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p><u>A1</u>: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
Electrical stability EMC immunity (operational)	4.6.5	<p>Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning.</p>

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

			<p>Response time at 3 K min<sup>-1</sup> was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.</p> <p>A1: 20 K min<sup>-1</sup> was not less than 30 s and did not exceed 30 s compared with the time obtained in 4.3.6</p>
--	--	--	--

Essential characteristics	Clauses in EN 54-7:2018	Regulatory classes	Performance
<b>Operational reliability:</b>		None	
Individual alarm indication	4.2.1		The visual indicator(s) are visible from a distance of 6 m in an ambient light intensity up to 500 lx.
Connection of ancillary devices	4.2.2		Open or short circuit failures of connection to ancillary device did not prevent the correct operation of the detector
Monitoring of detachable detectors	4.2.3		A fault condition is signaled when the detector is removed from the mounting base.
Manufacturer's adjustments	4.2.4		It is not possible to adjust the detector settings without the use of a special tool to access into the detector or use of a code to enabling entry into the panel programming software.
On site adjustment of response behavior	4.2.5		The mode(s) of operation are adjustable from the Control and Indicating Equipment by use of a loop communication protocol. Access to enable mode changes is by software control of the protocol communication.
Protection against the ingress of foreign bodies	4.2.6		The chamber is designed so that a sphere of diameter (1,3±0,05) mm cannot pass into the sensor chamber.
Response to slowly developing fires	4.2.7		The provision of "drift compensation" (e.g. to compensate for sensor drift due to the build-up of dirt in the detector), does not lead to a significant reduction in the detectors sensitivity to slowly developing fires.
Software controlled detectors	4.2.8		The software documentation and the software design complies with the requirements of EN 54-7:2018.
<b>Nominal activation conditions/sensitivity:</b>			
Repeatability	4.3.1	Threshold	Ratio of response values $m_{max}:m_{min} \leq 1.6$

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

		Lower response value, $m_{\max}:m_{\min} \geq 0.05 \text{ dB m}^{-1}$
Directional dependence	4.3.2	Ratio of response values $m_{\max}:m_{\min} \leq 1.6$ Lower response value, $m_{\max}:m_{\min} \geq 0.05 \text{ dB m}^{-1}$
Reproducibility	4.3.3	Ratio of response values $m_{\max}:\bar{m} \leq 1.33$ Ratio of the response values $\bar{m}:m_{\min} \leq 1.5$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$
<b>Response delay (response time):</b>		
Air movement	4.4.1	Ratio is $> 0.0625$ and $< 1.60$ and the point smoke detector did not emit a fault nor alarm signal during the test with aerosol-free air
Dazzling	4.4.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response thresholds $m_{\max}:m_{\min} \leq 1.6$
<b>Tolerance to supply voltage:</b>		
Variation in supply parameters	4.5	Ratio of response values $m_{\max}:m_{\min} < 1.6$ Lower response value, $m_{\min} \geq 0.05 \text{ dB m}^{-1}$
<b>Performance parameters under fire conditions:</b>		
Fire sensitivity	4.6	Evaluated as meeting the requirements of TF2 toTF5
<b>Durability of nominal activation conditions/Sensitivity:</b>		
temperature resistance		
Cold (operational)	4.7.1.1	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Dry heat (operational)	4.7.1.2	The specimen did not emit neither an alarm nor a fault signal and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Humidity resistance		
Damp heat, steady-state (operational)	4.7.2.1	The specimen did not emit neither an alarm nor a fault signal and ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Damp heat, steady-state (endurance)	4.7.2.2	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{\max}:m_{\min} \leq 1.6$
Corrosion resistance		
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	4.7.3	No fault signal, attributable to the endurance conditioning was given on reconnection of the

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.



		specimen and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Vibration resistance		
Shock (operational)	4.7.4.1	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Impact (operational)	4.7.4.2	No fault signal given from the specimen during the conditioning period or the additional 2 min. and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Vibration, sinusoidal (operational)	4.7.4.3	No fault signal given from the specimen during the conditioning and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Vibration, sinusoidal (endurance)	4.7.4.4	No fault signal, attributable to the endurance conditioning was given on reconnection of the specimen and Ratio of response values $m_{max}:m_{min} \leq 1.6$
Electrical stability EMC immunity (operational)	4.7.5	
a) Electrostatic discharge (operational)		
b) Radiated electromagnetic fields (operational)		
c) Conducted disturbances(operational)		
d) Fast transient bursts (operational)		
e) Slow high energy voltage surge (operational)		No alarm or fault signal given during the conditioning and Ratio of response values $m_{max}:m_{min} \leq 1.6$

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 <sup>1)</sup>	Pass
Operational reliability	4	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	Pass

1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices

Since the heat sensor can be used as a multisensor where the heat sensor enhances the response characteristics of the smoke detector (type), the product is tested and approved according to **CEA4021:2003**.

## Annex 2

## TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
DNV	99-1491 Revision: 02	1999-12-03, Rev. 02: 2000-01-04
DNV	2000-1178 Revision: 02	2000-02-15, Rev. 02: 2000-03-13
ANPI	BFS/DE/1057	2007-06-29
ANPI	BFS/REDI/154	2005-06-03 Addendum nr. 1: 2008-06-20 Addendum nr. 2: 2009-04-22
ANPI	BFS/REDI/234	2009-01-28
ANPI	BFS/REDI/155	2005-06-16 Addendum nr. 1: 2008-06-20 Addendum nr. 2: 2008-06-27
NEMKO	E18217.00	2018-11-15

## TECHNICAL BASIS

File Number	Title
BoM BHH-220	Bill of Materials Report
BoM BHH-320	Bill of Materials Report
BoM BHH-520	Bill of Materials Report
BoM BHH-520 N	Bill of Materials Report
BoM BHH-520 EX	Bill of Materials Report

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.