

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **BBL-100 Addressable indoor beacon with isolator**

The product fulfils the essential characteristic:

**See Annex 1**

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Autronica Fire and Security AS  
Bromstadvegen 59  
NO-7047 Trondheim  
Norway**

and produced in the manufacturing plant:

**CPA10061**

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

**EN 54-17:2005** : **Fire detection and fire alarm systems - Part 17: Short-circuit isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### **CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.**

This certificate was first issued on 2022-12-23 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2022-12-23**.



Chris Ellis  
Responsible for evaluation



Merete Poulsen  
Responsible for certification decision

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S**

Jernholmen 12, 2650 Hvidovre  
Tlf.: 36 34 90 90

E-mail: [info@dbicertification.dk](mailto:info@dbicertification.dk)  
[www.dbicertification.dk](http://www.dbicertification.dk)

Annex 1

**EXTENT**

**Type:**

BBL-100 Addressable indoor beacon with isolator

**Note:**

The beacon functionality is not included within the scope of this approval.

**Performance**

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 <sup>1)</sup>	Pass
Operational reliability	4 <sup>2)</sup>	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	Pass
1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices 2) There is no provision for connection of ancillary devices and this device does not incorporate a LED indicator. Therefore the clauses 4.2 and 4.3 are not applicable.		

The certificate shall be reproduced in extenso  
 – extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S**

Jernholmen 12, 2650 Hvidovre  
 Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk  
 www.dbicertification.dk

Annex 2

**TEST DOCUMENTATION**

Accredited Laboratory	Report no.	Date
BRE	TE 243617	2010-10-15
BRE	TE 243617-SW	2010-10-19

**TECHNICAL BASIS**

File Number	Title	Date
BBL-100 BOM	811039FULL-0002 SOL/RF/RL/R/S AUTRONICA BBL-100	2019-05-08
02C077	Critical Component List	2019-04, Rev. 3.0

The certificate shall be reproduced in extenso  
– extracts only with written permission from DBI Certification A/S.