

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

BBR-130 Addressable indoor base sounder with isolator

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

**Autronica Fire and Security AS
Bromstadvegen 59
NO-7047 Trondheim
Norway**

and produced in the manufacturing plant:

CPA10061

This attests that all provisions concerning the performance described in Annex ZA of the standard(s)

EN 54-3:2001/A1:2002/A2:2006 : Fire detection and fire alarm systems - Part 3: Fire alarm devices - Sounders

EN 54-17:2005 : Fire detection and fire alarm systems - Part 17: Short-circuit isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

CONSTANCY OF PERFORMANCE OF THE CONSTRUCTION PRODUCT.

This certificate was first issued on 2022-12-23 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The attached annexes form part of this certificate.

Date of issue: **2022-12-23.**



Chris Ellis
Responsible for evaluation



Merete Poulsen
Responsible for certification decision

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 1

EXTENT

Type:

BBR-130 Addressable indoor base sounder with isolator

Sounder Tones:

| Tone | Description | Sounder Pattern Information |
|------|---------------|---------------------------------------|
| a | General Alarm | 880Hz, 7*0.5 sec pulse & 1*5.5 |
| b | Evacuate | 880 Hz, 1 sec on / 1 sec off, forever |
| c | Alert | 880 Hz ON, forever |
| d | Bell Test | 0.5 sec on every 8 sec |
| e | Slow Whoop | 3.5 sec on / 0.5 sec off, 500-1200 Hz |

Performance

| Essential characteristics | Clauses in EN 54-3:2001/A1:2002/A2:2006 | Performance |
|---|---|-------------|
| Performance under fire conditions | 4.2, 4.3, 5.2, 5.3 | Pass |
| Operational reliability | 4.4, 4.5, 4.6, 5.4 | Pass |
| Durability of operational reliability and response delay; temperature resistance | 5.5, 5.6, 5.7, 5.8, 5.9 | Pass |
| Durability of operational reliability; humidity resistance | 5.8, 5.9, 5.10 | Pass |
| Durability of operational reliability; corrosion resistance | 5.11 | Pass |
| Durability of operational reliability; vibration resistance | 5.12 to 5.15 | Pass |
| Durability of operational reliability; electrical stability | 5.16 | Pass |
| Durability of operational reliability; resistance to ingress | 5.17 | Pass |
| 5.6 and 5.10 applies only to outdoor sounders or outdoor voice sounders. Therefore are these clauses not applicable for this device. 5.16 applies only to sounders or voice sounders with active electronic components | | |

| Essential characteristics | Clauses in EN 54-17:2005 | Performance |
|---|--------------------------|-------------|
| Performance under fire conditions | 5.2 ¹⁾ | Pass |
| Operational reliability | 4 ²⁾ | Pass |
| Durability of operational reliability; temperature resistance | 5.4, 5.5 | Pass |
| Durability of operational reliability; vibration resistance | 5.9 to 5.12 | Pass |
| Durability of operational reliability; humidity resistance | 5.6, 5.7 | Pass |
| Durability of operational reliability; corrosion resistance | 5.8 | Pass |
| Durability of operational reliability; electrical stability | 5.3, 5.13 | Pass |
| 1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices 2) There is no provision for connection of ancillary devices and this device does not incorporate a LED indicator. Therefore the clauses 4.2 and 4.3 are not applicable. | | |

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

DBI Certification A/S

Jernholmen 12, 2650 Hvidovre
Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk
www.dbicertification.dk

Annex 2

TEST DOCUMENTATION

| Accredited Laboratory | Report no. | Date |
|-----------------------|--------------|------------|
| BRE | TE 243617 | 2010-10-15 |
| BRE | TE 243617-SW | 2010-10-19 |

TECHNICAL BASIS

| File Number | Title | Date |
|-------------|---|-------------------|
| BBR-130 BOM | 666079FULL-0134 BASE SOUNDER BBR-130 AUTRONICA | 2019-05-08 |
| 02C077 | Critical Component List | 2019-04, Rev. 3.0 |

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.