

Certificate No. ICT 1003:2011

Project No. 90C101.34

| | |
|---|---|
| Applicant | Autronica Fire and Security AS Haakon VII's gate 4 7041 Trondheim |
| Manufacturer | Autronica Fire and Security AS Haakon VII's gate 4 7041 Trondheim |
| Factory | Autronica Fire and Security AS Haakon VII's gate 4 7041 Trondheim |
| System/model/type | AutoSafe Interactive Fire Detection System, Release 3.8 |
| The above product is certified according to the following standard(s) | Safety std.: IEC 61508:2000 series, part 1, 2, 3 and 4 Functional safety of electrical/electronic/programmable electronic safety-related systems |
| Safety Integrity Levels | The above product has the capability of SIL 1 and SIL 2 for safety related applications according to: IEC 61508:2000 series, part 1, 2, 3 and 4 |
| Validity | This certificate documents conformity with the standards shown. The certificate is valid as long as the applicable conditions, described in the certificate report, are complied with. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary. |
| Certificate Report | Report no SINTEF F20337 Certification of IFG system version 3.8 according to IEC 61508:2000 |

Date of issue 9th of September 2011

Name, Sign

Eldfrid Øfsti Øvstedal, Research Director

SINTEF ICT



Name, Sign

Thor Myklebust

SINTEF ICT