

MAY  
17-20  
2021



# SUMMIT

A VIRTUAL LEADERSHIP SYMPOSIUM

Learn more: [betterbuildingsolutioncenter.energy.gov/summit](https://betterbuildingsolutioncenter.energy.gov/summit)

U.S. DEPARTMENT OF  
**ENERGY**



---

# Best of the Betters: 2021 Better Project Presentations

Tuesday, May 18, 2021

2:00-3:15 pm ET



Eli Levine

U.S. Department of Energy

# Agenda

---

## Video Presentations

1. **3M** – Prasath Vinayagamoorthy (Senior Energy Engineer) & Brian Mohr (Maintenance Engineer)
2. **Flowers Foods** – Margaret Ann Marsh (VP Environmental & Sustainability)
3. **Graham Packaging** – Scott Christensen (Operations Engineering Manager)
4. **Lockheed Martin** – Michael Stein (Facilities Energy Manager)
5. **Nissan North America** – Brett Rasmussen (Senior Manufacturing Engineer)
6. **Owens Corning** – Don Scarsella (Energy Program Manager)
7. **SugarCreek Packing Co.** – Todd Jackson (Maintenance Administrator)
8. **Tyson Foods** – Alex Floyd (Senior Manager, Sustainability)

## Q&A Session

---

*3M – for implementing a real-time, battery-less steam trap cloud monitoring system that saves 10.6 million pounds of steam per year*

Prasath Vinayagamoorthy (Senior Energy Engineer) & Brian Mohr (Maintenance Engineer)

Submit Questions

[www.slido.com](http://www.slido.com) event code #DOE, Best of the Betters: Better Project Presentations



Science.  
Applied to Life.™

Energy Management

# Real-time, batteryless, cloud steam trap monitoring system

**Prasath Vinayagamoorthy**

**Brian Mohr**

May 18, 2021

# 3M Company

Since 1902...

## Our Vision


3M Technology Advancing Every Company

3M Products Enhancing Every Home

3M Innovation Improving Every Life



# Corporate Sustainability Goals



Raw Materials



Water



Climate & Energy



Health & Safety



Education & Development



## Climate & Energy

Improve energy efficiency indexed to net sales by 30 percent.

Increase renewable energy to 50% of total electricity use.


Reduce Scope 1 and 2 market-based GHG emissions by at least 50% by 2030, 80% by 2040, and achieve carbon neutrality in our operations by 2050.<sup>1,3</sup>

Help our customers reduce their GHGs by 250 million tons of CO<sub>2</sub> equivalent emissions through use of 3M products.

1. 2019 will be the baseline measure year for these new commitments
2. Expanded commitment from 10% between 2015 and 2025
3. Expanded 3M's 2025 goal to stay below 50% of our 2002 baseline, meaning 3M's 2030 Scope 1 and 2 emissions will now be reduced more than 85% from 2002 levels



# Strategies for Climate and Energy Goals



# Everactive System: Overview



Everactive entered the market with a self-powered IoT sensing technology application around steam traps.

The Eversensors are a unique technology that provide an easy connection to detect leaks on its own, reliably, without human intervention and the need for maintenance (ex: replacing batteries).

The sensor harvests energy from its surroundings through multiple sources including indoor solar, thermal gradients, RF, vibration and more.

It then connects to the cloud via ultra-low-power, proprietary integrated radios to communicate wirelessly to the cloud.


The sensor collects analog data of temperature, humidity, vibration, acceleration, and pressure for a digital front.



# EverActive System: Dashboard

Enhanced dashboard available to review the steam trap status, sensor status, energy loss, energy saved, cost loss and cost saved.

Receive email and text notification regarding the failure and failure details.



Trap Triage List

| Location                                       | Tag       | Days Failed | Cost     | State                             |
|--|-----------|-------------|----------|-----------------------------------|
| 3M-Brookings - M-3 Zone 3 Coil 2 High Pressure | 5-2.5-372 | 3           | -\$76.44 | Check Trap: Suspected Blowthrough |
| 3M-Brookings - M-3 Zone 3 Coil 1 High Pressure | 5-2.5-374 | 2           | -\$59.75 | Check Trap: Suspected Blowthrough |

This form is used to document the resolution of a steam trap issue. It includes the following fields and options:

- Title:** Confirm Resolution for M-3 Zone 3 Coil 2 High Pressure, 3M-Brookings, 5-2.5-372
- Type:** Blowthrough
- Timestamp:** 11/29/2020 7:26:00 AM
- Action:** View Steam Trap
- Instructions:** Please select at least one of the following:
- Trap inspected?:** Includes a date field (mm/dd/yyyy) and a "Status Confirmed?" checkbox.
- Trap replaced?:** Includes a date field (mm/dd/yyyy) and a "Status Confirmed?" checkbox.
- Footer:** A note stating "If status is confirmed, trap must be replaced to resolve this notification." and buttons for "Cancel" and "Resolve".

The notification alert contains the following information:

- Header:** everactive logo
- Alert Title:** Notification Alert: Blowthrough
- Asset Details:** 3M-Brookings, M-3 Zone 3 Coil 2 High Pressure, 5-2.5-372
- Timestamp:** 11/29/2020 7:26 AM UTC
- Message:** One of your assets has an alert from Evercloud. Please click on the link below to resolve or snooze your alert.
- Action:** A prominent "Resolve Notification" button.

# Brookings Pilot

## Pilot in Brookings, South Dakota (US)\*

|   |          |
|---|----------|
| Plant Operation                         | 24*7     |
| Monitored traps                         | 50       |
| Duration of trail                       | 6 months |
| Trap issues detected                    | 12       |
| Percentage of failed traps <sup>1</sup> | 24%      |
| No. of failed steam trap days - Before  | 45 days  |
| No. of failed steam trap days - After   | 12 days  |
| Pay back                                | 6 Months |

\*Estimates based on Napier's Equation for Steam Loss

<sup>1</sup> Typical failure rate is 10-15% across an entire production facility

## Benefits


|                             |             |
|-----------------------------|-------------|
| Emission reduction          | 0.55 MtCo2  |
| Cost Saving                 | 74%         |
| Steam Loss Saving           | 10,600 klbs |
| Maintenance time reduction  | 25-30%      |
| Quality Issues due to Steam | Nil         |
| Downtime due to Steam       | Nil         |
| Safety Risk                 | Zero risk   |



EverActive Sensors installed at 3M Brookings

# Corporate Replication

- The Corporate Energy Team is currently looking at increasing participation with other 3M sites for real-time steam trap monitoring.
- The team has put together a proposal for top management.
- Evaluate cost-savings for site to site based on actual condition.
- Evaluate cost-savings for different regions (LATAM, APAC, EMEA)



| USAC Proposal (16 Tier 1 Sites)      |            |
|--------------------------------------|------------|
| Steam trap Counts                    | 9371+      |
| Cost saving @15% failure rate:       | 24%        |
| Emission reduction @15% failure rate | 160 KtCO2  |
| Pay Back @15% failure rate           | 4.2 Months |
| Cost saving @10% failure rate        | 12%        |
| Emission reduction @10% failure rate | 94 KtCO2   |
| Pay Back @10% failure rate           | 6.2 Months |

# 3M Energy Management Recognition



Clean Energy Ministerial Global Awards

2019 – Excellence in Energy Management (Corporate)

2017,2019 – Insight Award (3M Company, 3M Canada)

Dow Jones Sustainability Index

2019 – 20<sup>th</sup> Consecutive year of recognition



DOE BBBP

2021 - Better Projects Award – Batteryless, cloud steam trap monitoring system

2020 – iTEAM Awards (Cynthiana & Cottage Grove)

Association of Energy Engineers

2019 – Corporate Energy Management

2019 – Energy Engineer of the Year Award (Canada)



Canadian Industry Program for Energy Conservation (CIPEC)

2014/2018 – Corporate Stewardship

IESO (Crown Corp.)

2018 – Energy Manager of the Year Award



Questions?

---

**Flowers Foods, Inc.** – *for redesigning and rebuilding an existing bread plant to produce organic bread and includes a variety of sustainability features that reduced annual energy and water consumption by 22% and 64%, respectively*

Margaret Ann Marsh (VP Environmental & Sustainability)

Submit Questions

[www.slido.com](https://www.slido.com) event code #DOE, Best of the Betters: Better Project Presentations



---

# Graham Packaging – *for upgrading a facility air and water management system that led to an 11% reduction in annual electricity usage*

Scott Christensen (Operations Engineering Manager)

Submit Questions

[www.slido.com](http://www.slido.com) event code #DOE, Best of the Betters: Better Project Presentations



Better Plants Presentation | 18 May 2021

# Florence Energy Savings Project



**Graham**  
Packaging

# The Graham Story

At the heart of the new Graham brand is the idea of being

**“Always Inspired.”**

Always Inspired isn't just a concept, it's a mentality. A commitment to and focus on the possibilities for a better product, a happier customer, and a cleaner world.

## We are the Experts in

### SUSTAINABLE

Our commitment to sustainability goes beyond just the bottle. We are committed to minimizing our impact through sustainable operations and creating a circular economy.



### INNOVATIVE

Superior technology with a long history of innovation in PET and Polyolefin. We provide safe, attractive and convenient packaging that meets the demands of today's consumer.

### CREATIVE

We have the talent, tools and experience to help craft new bottle shapes to meet branding and manufacturing needs of our customers.

## Packaging Solutions

# Our Commitment to Sustainability Goes Beyond Just the Bottle.

We recognize that climate change is real, and we're taking steps to reduce our greenhouse gas (GHG) emissions. Those efforts include lightweighting packaging, diverting plastics from landfills, developing lower carbon products, offering co-locations with customers and reducing our energy usage.

## Minimizing Our Impact

There isn't a bottle in the world that threw itself in the trash. All parties – from plastic manufacturers to recyclers to consumers – must do their part to create a circular economy.



### Up to 52% Lower ESG Risk Than Our Direct Competitors.

Graham Packaging was named **best of all rated plastic, glass and metal packaging companies** in our risk profile in the areas of environmental, social and governance (ESG) from Sustainalytics.



Increase Recycled Content



Lightweighting



Sustainable Operations

# Our Goals are Your Goals!

We work to always be the partner of choice by helping customers meet their sustainability goals now and in the future. We have our sights set on protecting the planet, and we know we'll be ready to meet the needs of the markets we serve. And in turn, we'll help our customers be ready, too.

## 100%

Committed to designing for recyclability across all products to achieve our goal of 100% recyclability by 2025.



## 20%

Committed to increasing our use of PCR by incorporating an average of 20% PCR across all bottles by 2025



## 25%

As a member of the U.S. Department of Energy's Better Plants Program, we've committed to achieving 25% energy reduction by 2028.



## 30%

From our 2020 baseline, we've committed to a sustainability goal of 30% GHG emission reduction by 2030.



## Our Commitments to Creating a Better Tomorrow

We are positioning ourselves for the future through strong sustainability partnerships and commitments to several long-term goals.



# Project Kick-Off

- Graham's Florence, KY plant produces 283 million PET bottles and 384 million preforms.
- A team tasked with looking at operational efficiencies set a goal to provide energy and water savings.
  - Started by completing an assessment and in-depth audit of the facility. During this process, the team compiled records of production demand, kilowatt usage and water usage.
  - The analysis showed that significant energy savings were attainable through power and water usage controls.
- We identified that a set of comprehensive energy efficiency measure packages, instead of a standalone measure, would have an estimated return on investment of less than 24 months.
- A multi-disciplinary team of different stakeholders, include a technology company, a control system developer and a utility company, was formed to execute the project.



# Energy Savings Solutions



- During the team's discussions, it was determined that any energy savings measures implemented needed to also ensure that the plant could continue to operate the equipment at peak performance. Defined the project to include:
  - Variable speed drives on cooling tower pumps
  - Variable speed drives on chiller pumps and cooling tower fans
  - Replacement of an older inefficient centrifugal chiller with a new VSD Magnetic Bearing technology chiller
  - Precision air flow regulators on all bottle blow machines.
- Also installed comprehensive systems management controls for both air and water systems to meet production demand requirements using temperature, flow and pressure with real-time data.

# Overcoming Obstacles

- The project was not without expected challenges. Significant barriers included:
  - The need to maintain precise water temperatures, flows and pressure to key systems and production equipment.
  - The need to limit the downtime of the equipment during implementation as to continue to meet customer demand.
- How we overcame them:
  - Building to the project thermal control valves.
  - Combining the developed project timeline with other projects that were completed during scheduled shutdowns of the facility in order to lessen the impact on production.





# Project Implementation and Execution


- Working in partnership with IZ Systems, Johnson Controls, and Duke Energy, Graham was able to create and implement a vigorous timeline:
  - Started first quarter of 2019, completed in July 2019
- To help stay on budget, the maintenance staff at the facility was trained in the operation, management, preventative maintenance, and limitations of the newly installed system.
  - Also proved to be a cost savings in the future by allowing Graham staff to continue to provide the proper care and maintenance of the equipment.
- Johnson Controls provided the York YMC2 VSD chiller, which can handle condenser water temperatures below 50°F.
  - This allows the plant to take advantage of the colder environmental temperatures within the region to lower energy use while maintaining a production chilled water temperature, and increase cycles of concentration of the cooling towers due to less evaporation created by heat load of the system.
- IZ Systems provided the audit, instrumentation and measurements systems along with its assistance in engineering, installation and implementation of the new system, and assisting the plant to work with Duke Energy to secure any and all rebates and incentives.



# Outcomes

- Impressed with the real savings that were recorded and tracked using remote access to the management system.
- By putting in metrics to track water and kilowatt usage, Graham was able to recognize and reduce the required energy to produce air and chilled water for the process of bottle and preform production.
  - Saw an 11% reduction in kWh usage from 2018 to the end of 2020.
  - Saw energy usage drop from an average of 1,267 kWh/1,000 lbs produced in 2018 to 1,127 kWh/1,000lbs produced in 2020.
- Total kWh savings since project implementation of roughly 7,497,953 kWh in 18 months.

Graham Florence IZ Total Energy Savings Summary



# Sustained Impact



- With the project success of the Florence, Kentucky facility, Graham has strengthened its commitment to investing in more of their facilities with this technology.
- So far, Graham has implemented similar energy saving projects at five plants throughout the United States, with plans to grow the program even further.
- While this technology is not a one-size-fits-all solution for eliminating excessive energy usage, it is an example of Graham's commitment to reduce energy usage throughout all of its 60+ locations, and its work towards its long-term goal of achieving 25% energy reduction by 2028.



**Graham**  
Packaging

---

**Lockheed Martin** – *for optimizing a facility's cogeneration system and central utility plant, saving \$1.5 million in annual energy costs with a 2.2-year payback*

Michael Stein (Facilities Energy Manager)

Submit Questions

[www.slido.com](http://www.slido.com) event code **#DOE**, Best of the Betters: Better Project Presentations



# Lockheed Martin / Sikorsky Central Utility Plant Optimization Project

May 18, 2021

Site Project Manager – Jonathan Kuczenski, Sikorsky Aircraft Corporation, Stratford, CT

Presenter / Energy Manager – Michael Stein, Sikorsky Aircraft Corporation, Stratford, CT





**SIKORSKY**  
A LOCKHEED MARTIN COMPANY



**GO**  
**GREEN** 2030



# SIKORSKY



Sikorsky Aircraft  
Corporation; Stratford, CT

esh

LOCKHEED MARTIN



# Central Utility Plant




## **Cogeneration (pre-existing conditions):**

- 10.265 MW maximum output capacity
- Installed in 2012
- Provides 75% of facility's annual electric load
- Waste heat used to satisfy heating loads



# Central Utility Plant Optimization – Phase 1




# Central Utility Plant Optimization – Phase 2



## **Cogen Challenges :**

- 600 kW minimum import requirement
- 5MW minimum output capacity on Cogen
- Demand reductions
  - Time of Day
  - Energy Conservation Measures (ECM)
  - 550 kW Steam Turbine Generator

# Central Utility Plant Optimization – Phase 2



## Interconnection Agreement:

- Operate new 550-kW STG
- 1 MW export limit
- Elimination of 600 kW import requirement

# Savings Overview



## Phase 1 – Annual Savings:

- Absorption Chiller = 635,000 kWh
- Air Compressor = 732,000 kWh
- 550-kW STG = 1,800,000 kWh

## Phase 2 – Annual Savings:

- Avoided Import = 7,100,000 kWh
- Export = 3,200,000 kWh

## Total Project Annual Savings

- Import Energy = 10,267,000 kWh
- Export Energy = 3,200,000 kWh
- Cost Avoidance = \$1.5M

**Payback = 2.2 years**

***LOCKHEED MARTIN***



---

**Nissan North America** – *for upgrading air handling unit-controls to enable automatic maintenance of temperature and air quality, saving over \$200,000 and 1,800 metric tons of CO2 per year*

Brett Rasmussen (Senior Manufacturing Engineer)

Submit Questions

[www.slido.com](http://www.slido.com) event code #DOE, Best of the Betters: Better Project Presentations



2021 Better Project Award from  
U.S. Department of Energy's Better Plants Program



# U.S. FOOTPRINT



Nissan North America  
Headquarters (Franklin,  
Tenn.)




Vehicle Assembly Plant  
(Canton, Miss.)



Vehicle Assembly Plant  
(Smyrna, Tenn.)



Nissan Technical Center  
(Farmington Hills, Mich.)



Powertrain Plant  
(Decherd, Tenn.)


More than **22,000** employees  
in the U.S.



Arizona Technical Center  
(Chandler, Ariz.)



Nissan Design America  
(San Diego, Calif.)



Nissan Motor Acceptance Corporation  
(Dallas, Texas)




Advanced Research Center  
(Silicon Valley, Calif.)



# U.S. MANUFACTURING



**NISSAN GROUP  
OF NORTH AMERICA**



# Accelerating toward carbon neutrality

**NISSAN**  
MOTOR CORPORATION

Battery innovations for cost-competitive and more efficient EVs

Greater energy efficiency of our e-POWER electrified powertrains

Electrifying every all-new vehicle offering in key markets by early 2030s

Develop a battery ecosystem to support decentralized renewable energy generation

Greater energy and material efficiencies during the manufacturing process

2050 Carbon neutrality across vehicle life cycle

## Electrification

- Nissan Ariya
- e-Power (Electric Powertrain w/Generator)

## Battery Innovations


- Battery to Grid (Vehicle to X)
- Battery Re-Use
- Solid State Batteries

## Nissan Intelligent Factory

- Bringing Craftsmanship to Robots
- Making Better Workplaces with Robots
- Building the Future of Mobility

## Greener Supply

- Energy Targets
- TVA Targets






# Nissan Canton Plant AHU Control Upgrade




# Canton Plant



# Typical AHU



# All Units have VFDs on the Fan Motors



# Canton Plant Temp Overview

[Home](#)



| AHU_40_06    | AHU_40_07    | AHU_40_08    | AHU_40_09    | AHU_40_10    | AHU_40_11    | AHU_40_12    |
|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| Column N41   | Column R41   | Column T40   | Column V40   | Column X40   | Column Z40   | Column AB40  |
| 75.1 °F      | 74.9 °F      | 73.9 °F      | 73.2 °F      | 72.1 °F      | 73.1 °F      | 71.8 °F      |
| 41.0 Hz      | 21.4 Hz      | 37.8 Hz      | 37.9 Hz      | 49.3 Hz      | 35.8 Hz      | 43.5 Hz      |
| CLG VLV POS: | CLG VLV POS: | CLG VLV POS: | CLG VLV POS: | CLG VLV POS: | CLG VLV POS: | CLG VLV POS: |
| 1.4 %        | 73.8 %       | 2.8 %        | 3.6 %        | 99.2 %       | 1.4 %        | 100.0 %      |
|              |              |              |              |              |              |              |
| AHU_40_15    | AHU_40_18    | AHU_40_19    | AHU_40_20    | AHU_40_21    |              |              |
| Column N38N  | Column P35   | Column U35   | Column X35   | Column AB35  |              |              |
| 76.1 °F      | 73.5 °F      | 72.8 °F      | 72.0 °F      | 70.7 °F      |              |              |
| 28.2 Hz      | 23.9 Hz      | 36.4 Hz      | 41.1 Hz      | 40.8 Hz      |              |              |
| CLG VLV POS: | CLG VLV POS: | CLG VLV POS: | CLG VLV POS: | CLG VLV POS: |              |              |
| 1.4 %        | 2.2 %        | 38.6 %       | 99.7 %       | 98.8 %       |              |              |




Home Points

# AHU\_40\_08

EF1-C OFF

EF2-C OFF



# Unit without Controls

Fluke Energy Analyze Plus 2.1 - [ES.070 (SN 34100018).fca]

File View Settings Help

Download Data Open File New File Export Report

Project Manager Energy Study PQ+ Study Advanced Report

RMS Power Demand Calendar View Fundamental Power V, A, Hz, THD

V, A, Hz, THD overview table

Full Screen Copy Add Bookmark

| ES.070                |                                  | Logging Information              |                                  |                                 |  |
|-----------------------|----------------------------------|----------------------------------|----------------------------------|---------------------------------|--|
| <b>Voltage [V]</b>    | <b>AB</b>                        | <b>BC</b>                        | <b>CA</b>                        | <b>N</b>                        | <b>Study type:</b><br>Energy study<br><b>Topology:</b><br>3-ph IT<br><b>Start date:</b><br>2/7/2019 11:13:00 AM<br><b>End date:</b><br>2/9/2019 11:34:00 AM<br><b>Duration:</b><br>2d 0h 21m 0s<br><b>Averaging interval:</b><br>1min<br><b>Number of averaging intervals:</b><br>2901 (2901)<br><small>* ... series contained invalid values that have been discarded for the shown result.</small> |
| Max                   | 482.3 V<br>2/9/2019 1:46:00 AM   | 480.3 V<br>2/9/2019 12:06:00 AM  | 481.3 V<br>2/7/2019 11:14:00 AM  |                                 |  |
| Avg                   | 477.1 V                          | 475.2 V                          | 473.4 V                          |                                 |  |
| Min                   | 0.0000 V<br>2/7/2019 11:14:00 AM | 0.0000 V<br>2/7/2019 11:14:00 AM | 0.044 V<br>2/7/2019 11:14:00 AM  |                                 |  |
| <b>Current [A]</b>    | <b>A</b>                         | <b>B</b>                         | <b>C</b>                         | <b>N</b>                        |  |
| Max                   | 200.4 A<br>2/9/2019 12:39:00 AM  | 197.2 A<br>2/9/2019 12:39:00 AM  | 219.4 A<br>2/9/2019 12:39:00 AM  |                                 |  |
| Avg                   | 50.4 A                           | 51.0 A                           | 51.9 A                           |                                 |  |
| Min                   | 0.0000 A<br>2/7/2019 11:14:00 AM | 0.0000 A<br>2/7/2019 11:14:00 AM | 0.0000 A<br>2/7/2019 11:14:00 AM |                                 |  |
| <b>Frequency [Hz]</b> |                                  |                                  |                                  |                                 |  |
| Max                   | 61.78 Hz<br>2/7/2019 11:14:00 AM |                                  |                                  |                                 |  |
| Avg                   | 60.01* Hz                        |                                  |                                  |                                 |  |
| Min                   | 57.08 Hz<br>2/7/2019 11:14:00 AM |                                  |                                  |                                 |  |
| <b>THD-V [%]</b>      | <b>AB</b>                        | <b>BC</b>                        | <b>CA</b>                        | <b>N</b>                        |  |
| Max                   | 21.8 %<br>2/7/2019 11:14:00 AM   | 37.4 %<br>2/7/2019 11:14:00 AM   | 25.6 %<br>2/7/2019 11:14:00 AM   |                                 |  |
| Avg                   | 5.0* %                           | 5.0* %                           | 5.1* %                           |                                 |  |
| Min                   | 3.9 %<br>2/9/2019 6:27:00 AM     | 3.9 %<br>2/9/2019 5:55:00 AM     | 3.9 %<br>2/9/2019 6:46:00 AM     |                                 |  |
| <b>THD-A [%]</b>      | <b>A</b>                         | <b>B</b>                         | <b>C</b>                         | <b>N</b>                        |  |
| Max                   | 62.2* %<br>2/8/2019 3:03:00 AM   | 65.1* %<br>2/8/2019 4:09:00 PM   | 63.0* %<br>2/8/2019 4:04:00 PM   |                                 |  |
| Avg                   | 52.3* %                          | 55.2* %                          | 54.1* %                          |                                 |  |
| Min                   | 11.2* %<br>2/7/2019 10:25:00 PM  | 11.9* %<br>2/7/2019 10:25:00 PM  | 11.8* %<br>2/7/2019 10:25:00 PM  |                                 |  |
| <b>Unbalance [%]</b>  | <b>AB</b>                        | <b>BC</b>                        | <b>CA</b>                        | <b>Total</b>                    |  |
| Max                   |                                  |                                  |                                  | 0.590* %<br>2/8/2019 7:47:00 PM |  |
| Avg                   |                                  |                                  |                                  | 0.468* %                        |  |
| Min                   |                                  |                                  |                                  | 0.345* %<br>2/7/2019 1          |  |

51.1 Amps



# AHU Controls

Fluke Energy Analyze Plus 2.1 - [ES.069 (SN 34100018).fca]

File View Settings Help

Download Data Open File New File Export Report

Project Manager Energy Study PQ+ Study Advanced Report

RMS Power Demand Calendar View Fundamental Power V, A, Hz, THD

V, A, Hz, THD overview table

ES.069

|                       | AB                                | BC                              | CA                               | N                                | Logging Information  |
|-----------------------|-----------------------------------|---------------------------------|----------------------------------|----------------------------------|--|
| <b>Voltage [V]</b>    |                                   |                                 |                                  |                                  |  |
| Max                   | 501.6 V<br>2/6/2019 3:07:00 PM    | 482.1 V<br>2/7/2019 4:14:00 AM  | 479.9 V<br>2/7/2019 4:14:00 AM   |                                  | <b>Study type:</b><br>Energy study<br><b>Topology:</b><br>3-ph IT<br><b>Start date:</b><br>2/6/2019 3:06:00 PM<br><b>End date:</b><br>2/7/2019 11:12:00 AM<br><b>Duration:</b><br>20h 6m 0s<br><b>Averaging interval:</b><br>1min<br><b>Number of averaging intervals:</b><br>1206 (1206)<br><small>* ... series contained invalid values that have been discarded for the shown result.</small> |
| Avg                   | 476.8 V                           | 475.9 V                         | 473.8 V                          |                                  |  |
| Min                   | 0.0000 V<br>2/6/2019 3:07:00 PM   | 0.0000 V<br>2/6/2019 3:07:00 PM | 0.0000 V<br>2/6/2019 3:07:00 PM  |                                  |  |
| <b>Current [A]</b>    |                                   |                                 |                                  |                                  |  |
| Max                   | 66.87 A<br>2/7/2019 11:12:00 AM   | 51.88 A<br>2/6/2019 3:32:00 PM  | 54.03 A<br>2/6/2019 3:32:00 PM   |                                  |  |
| Avg                   | 21.22 A                           | 21.39 A                         | 23.95 A                          |                                  |  |
| Min                   | 0.0000 A<br>2/7/2019 11:09:00 AM  | 0.0000 A<br>2/6/2019 3:07:00 PM | 0.0000 A<br>2/7/2019 11:09:00 AM |                                  |  |
| <b>Frequency [Hz]</b> |                                   |                                 |                                  |                                  |  |
| Max                   | 60.46* Hz<br>2/7/2019 11:10:00 AM |                                 |                                  |                                  |  |
| Avg                   | 59.99* Hz                         |                                 |                                  |                                  |  |
| Min                   | 57.93* Hz<br>2/7/2019 11:10:00 AM |                                 |                                  |                                  |  |
| <b>THD-V [%]</b>      |                                   |                                 |                                  |                                  |  |
| Max                   | 10.5* %<br>2/7/2019 11:10:00 AM   | 18.4* %<br>2/7/2019 11:10:00 AM | 11.6* %<br>2/7/2019 11:10:00 AM  |                                  |  |
| Avg                   | 5.5* %                            | 5.4* %                          | 5.7* %                           |                                  |  |
| Min                   | 4.9* %<br>2/6/2019 3:09:00 PM     | 4.9* %<br>2/7/2019 2:03:00 AM   | 5.1* %<br>2/6/2019 3:09:00 PM    |                                  |  |
| <b>THD-A [%]</b>      |                                   |                                 |                                  |                                  |  |
| Max                   | 182.3* %<br>2/6/2019 3:09:00 PM   | 203.9* %<br>2/6/2019 3:09:00 PM | 189.0* %<br>2/6/2019 3:09:00 PM  |                                  |  |
| Avg                   | 81.4* %                           | 81.9* %                         | 74.3* %                          |                                  |  |
| Min                   | 48.5* %<br>2/6/2019 3:32:00 PM    | 50.4* %<br>2/6/2019 3:32:00 PM  | 30.2* %<br>2/6/2019 3:11:00 PM   |                                  |  |
| <b>Unbalance [%]</b>  |                                   |                                 |                                  |                                  |  |
| Max                   |                                   |                                 |                                  | 9.889* %<br>2/7/2019 11:09:00 AM |  |
| Avg                   |                                   |                                 |                                  | 0.382* %                         |  |
| Min                   |                                   |                                 |                                  | 0.259* %<br>2/7/2019 5:27:00     |  |

22.186 Amps

Better Plants CHALLENGE U.S. DEPARTMENT OF ENERGY

ENERGY STAR PARTNER

V, A, Hz, THD graph

# Trim Shop Power Usage



Device Diagram Show Table



Thank you





---

Owens Corning – *for implementing an advanced HVAC control system at two facilities that optimizes the use of outside air and adjusts equipment sequences and setpoints, saving a combined \$350,000 per year*

Don Scarsella (Energy Program Manager)

Submit Questions

[www.slido.com](https://www.slido.com) event code #DOE, Best of the Betters: Better Project Presentations




# Adaptive Chilled Water Control System

## Owens Corning

Don Scarsella  
May 18, 2021

# OWENS CORNING AT A GLANCE



Serving residential, commercial, and industrial markets

INSULATION | ROOFING | COMPOSITES



# OWENS CORNING INNOVATION IS ALL AROUND US

How We **Move**



Where We **Live**



What We **Do**



How We **Power Our Lives**



And More!


# WHAT SUSTAINABILITY MEANS TO US



## NET-POSITIVE COMPANY ASPIRATION

---

“Meeting the needs of the present while leaving the world a better place for the future.”




# DEMAND SIDE ENERGY MANAGEMENT AT OWENS CORNING


- Plant Energy Teams
- Assessments and Kaizens (Treasure Hunts)
- Dedicated Energy Project Fund
- Low Cost / No Cost Implementations
- Best Practice Sharing
- Reporting, Metrics, Scorecards, Software Tools
- Working across the organization to achieve goals
- Replication
- Benchmarking
- Communications
- Taking advantage of the Better Plants Program!




# CHILLED WATER SYSTEM COMPONENTS



# Project Timeline



# Operator Interface





Copyright © 2021 Owens Corning. All Rights Reserved.

THE PINK PANTHER™ & © 1964–2021 Metro-Goldwyn-Mayer Studios Inc. All Rights Reserved

---

**SugarCreek Packing Co.** – *for utilizing a sonic imaging tool to improve leak detection surveys in a plant's compressed air system, leading to energy cost and non-energy benefits totaling \$60,000 per year*

Todd Jackson (Maintenance Administrator)

Submit Questions

[www.slido.com](https://www.slido.com) event code #DOE, Best of the Betters: Better Project Presentations





# Leak Detection Utilizing Fluke ii900 Ultrasonic Imager



# Leak Detection

## Leaks can be a significant source of wasted Energy-

- Leak detection is most often done utilizing devices with directional microphones, amplifiers, and audio filters, which utilize either earphones or visual indicators to help detect the leak.
- These devices typically need to be used during a period of no or low production to provide the best results
- An inefficient leak detection program can result in up to a 30% reduction in the efficiency of a compressed air system.

## Costs Money and Time

- Compressed air systems at the Washington Court House facility accounts for roughly 15% of the energy use for the building.
- Typically, personnel would manually survey the 120,000 sq ft and would hire external contractors to make trips to the facility upwards of 20 times per year to fix leaks in multiple systems.

## Through the Better Plants Program Enabled We:

- Request the Ultrasonic imager via our Technical Accounts Manager
- Received the Ultrasonic imager within a few weeks with no shipping costs
- Was able to utilize the device for 2 weeks.

## Success!

- In two weeks, time, not only were we able to check the compressed air system for leaks. We also were able to find leaks in remote areas and difficult overhead locations, along the ceiling in fire suppression systems as well as in our Nitrogen system.



# Outcomes


## Saved Money and Time:

Instead of taking upwards of 150 hours to locate a minimal number of leaks. The sonic imager enabled personnel to walk the entire production area – roughly 55,000 sq ft. in 20 hours while production was running!

About 30 leaks were located during this audit including some that would have previously gone undetected due to the size and location of the leak.



# High Temperature Area



## Cost Savings

- Reduce contractor visits
- Reduce maintenance costs
- Reduce labor costs
- Reduce energy loss


The ability to survey pipes located in elevated locations without the use ladders or scaffolding reduced risk to personnel and reduced time to perform leak checks



Overhead Leaks Detected



# Out Of Reach Areas



## Sustained Impact

The newer technology improved the efficiency of leak detection program, streamlined compressor operations, and expanded leak surveillance to include other plant systems (steam, vacuum, and nitrogen).

The use of the Ultra Sonic imager has allowed for:

- More frequent leak checks,
- Leak identification by frequency and location,
- Identifying high occurrence areas, leading to possible changes in equipment,
- Improved maintenance practices and specifications.



# THANK YOU



# SugarCreek™

Brandworthy Food Solutions™

Since 1966

[SugarCreek.com](http://SugarCreek.com)





---

**Tyson Foods** – *for leveraging Virtual In-Plant Trainings on industrial refrigeration systems to help identify annual energy savings opportunities of more than \$4 million*

Alex Floyd (Senior Manager, Sustainability)

Submit Questions

[www.slido.com](https://www.slido.com) event code #DOE, Best of the Betters: Better Project Presentations

# Utilizing Virtual In-Plant Training During the Pandemic


- Industrial Refrigeration



U.S. Department of Energy's Better Buildings, Better Plants Summit

May 18, 2021

**THE PROTEIN COMPANY™**



*“Continuous learning  
is nothing without  
continuous doing.”*

*Richie Norton*

# How do we drive success during a pandemic?



File Home Insert Page Layout Formulas Data Review View Developer Help EnPI Share Comments

N38

1 **Tyson Foods**

2 **AMMONIA REFRIGERATION SYSTEM ENERGY EFFICIENCY TOOL, Version 1.6**

3

4 **AMMONIA REFRIGERATION SYSTEM BASIC DATA**

5

6 **Plant**

7 **Business Unit**

8 **Division**

9 **City**

10

11 **Annual kWh**  kWh

12 **Annual Electricity Cost**

13 **Avg Electric Rate**  \$/kWh

14

| Refrigeration System        | Energy Consumption | Energy Cost  | % of Total Electricity |
|-----------------------------|--------------------|--------------|------------------------|
| <a href="#">Compressors</a> | 8,129,596          | \$561,493.63 | 41.8%                  |
| <a href="#">Condensers</a>  | 1,052,817          | \$72,715.81  | 5.4%                   |
| <a href="#">Evaporators</a> | 788,628            | \$54,468.80  | 4.1%                   |
|                             |                    |              | <b>51%</b>             |

16

| Measure   | Energy Savings                       | Energy Cost Savings | % of Total Electricity |
|---|--------------------------------------|---------------------|------------------------|
| <a href="#">Reduce Discharge Pressure</a>             | 60,940                               | \$4,209.02          | 0.3%                   |
| <a href="#">Increase Suction Pressure</a>             | 1,523,033                            | \$105,192.63        | 7.8%                   |
| <a href="#">Compressor Sequencing</a>                 | 585,744                              | \$40,456.05         | 3.0%                   |
| <a href="#">Superheat</a>                             | -                                    | -                   | -                      |
| <a href="#">Non-Condensables</a>                      | *Add to Discharge Pressure Reduction |                     |                        |
| <a href="#">Optimize Defrost</a>                      |                                      |                     |                        |
| <b>Total Refrigeration Energy Savings Opportunity</b> | <b>2,169,718</b>                     | <b>\$149,857.70</b> |                        |

22

23

24

25

26

27

28

29

30

**Compressors Condensers Evaporators**

| Component   | Percentage |
|-------------|------------|
| Compressors | 81%        |
| Condensers  | 11%        |
| Evaporators | 8%         |

Summary Compressors Condensers Evaporators Discharge Pressure Increase Suction Temp Compressor Sequencing Superheat Non-Condensab ...









File Home Insert Page Layout Formulas Data Review View Developer Help EnPI Share Comments

N38

1 **Tyson Foods**

2 **AMMONIA REFRIGERATION SYSTEM ENERGY EFFICIENCY TOOL, Version 1.6**

3

4 **AMMONIA REFRIGERATION SYSTEM BASIC DATA**

5

6 **Plant**

7 **Business Unit**

8 **Division**

9 **City**

10

11 **Annual kWh**  kWh

12 **Annual Electricity Cost**

13 **Avg Electric Rate**  \$/kWh

14

| Refrigeration System        | Energy Consumption | Energy Cost  | % of Total Electricity |
|-----------------------------|--------------------|--------------|------------------------|
| <a href="#">Compressors</a> | 8,129,596          | \$561,493.63 | 41.8%                  |
| <a href="#">Condensers</a>  | 1,052,817          | \$72,715.81  | 5.4%                   |
| <a href="#">Evaporators</a> | 788,628            | \$54,468.80  | 4.1%                   |
|                             |                    |              | <b>51%</b>             |

16

| Measure                                   | Energy Savings                       | Energy Cost Savings | % of Total Electricity |
|---|--------------------------------------|---------------------|------------------------|
| <a href="#">Reduce Discharge Pressure</a> | 60,940                               | \$4,209.02          | 0.3%                   |
| <a href="#">Increase Suction Pressure</a> | 1,523,033                            | \$105,192.63        | 7.8%                   |
| <a href="#">Compressor Sequencing</a>     | 585,744                              | \$40,456.05         | 3.0%                   |
| <a href="#">Superheat</a>                 | -                                    | -                   | -                      |
| <a href="#">Non-Condensables</a>          | *Add to Discharge Pressure Reduction |                     |                        |
| <a href="#">Optimize Defrost</a>          |                                      |                     |                        |

29 **Total Refrigeration Energy Savings Opportunity**

30

**Compressors Condensers Evaporators**

| Component   | Percentage |
|-------------|------------|
| Compressors | 81%        |
| Condensers  | 11%        |
| Evaporators | 8%         |

Summary Compressors Condensers Evaporators Discharge Pressure Increase Suction Temp Compressor Sequencing Superheat Non-Condensab ...

## Reducing Discharge Pressure

### What Drives Discharge Pressure Setpoint?

- Condenser Capacity / Heat Rejection (Ex: Higher in the summer because of high outdoor wetbulb temps)
- Liquid Injection Oil Cooling Requirements
- DX Valve Requirements
- Defrost Pressure Requirements
- Can Cause Oil Carry Over in Compressors at Lower Head Pressures

### Energy Efficiency Rules of Thumb

\* Reducing Discharge Temp Increases Compressor Efficiency 1.5% per 1°F Increase

|                   | Season | # Months per Year | System     | Total kWh | Current            | Proposed           | Annual kWh Savings |
|-------------------|--------|-------------------|------------|-----------|--------------------|--------------------|--------------------|
|                   |        |                   |            |           | Discharge Pressure | Discharge Pressure |                    |
| Engine Room A,B,C | Summer |                   | High Stage |           |                    |                    |                    |
|                   | Fall   |                   | High Stage |           |                    |                    |                    |
|                   | Winter |                   | High Stage |           |                    |                    |                    |
|                   | Spring |                   | High Stage |           |                    |                    |                    |

### What limits your plant's ability to lower discharge pressure?









File Home Insert Page Layout Formulas Data Review View Developer Help EnPI Share Comments

N38

A B C D E F G H I J K L

1 **Tyson Foods**

2 **AMMONIA REFRIGERATION SYSTEM ENERGY EFFICIENCY TOOL, Version 1.6**

3

4 **AMMONIA REFRIGERATION SYSTEM BASIC DATA**

5

6 **Plant**

7 **Business Unit**

8 **Division**

9 **City**

10

11 **Annual kWh**  kWh

12 **Annual Electricity Cost**

13 **Avg Electric Rate**  \$/kWh

14

15

| Refrigeration System        | Energy Consumption | Energy Cost  | % of Total Electricity |
|-----------------------------|--------------------|--------------|------------------------|
| <a href="#">Compressors</a> | 8,129,596          | \$561,493.63 | 41.8%                  |
| <a href="#">Condensers</a>  | 1,052,817          | \$72,715.81  | 5.4%                   |
| <a href="#">Evaporators</a> | 788,628            | \$54,468.80  | 4.1%                   |
|                             |                    |              | <b>51%</b>             |

16

17

18

19

20

21

| Measure   | Energy Savings                       | Energy Cost Savings | % of Total Electricity |
|---|--------------------------------------|---------------------|------------------------|
| <a href="#">Reduce Discharge Pressure</a>             | 60,940                               | \$4,209.02          | 0.3%                   |
| <a href="#">Increase Suction Pressure</a>             | 1,523,033                            | \$105,192.63        | 7.8%                   |
| <a href="#">Compressor Sequencing</a>                 | 585,744                              | \$40,456.05         | 3.0%                   |
| <a href="#">Superheat</a>                             | -                                    | -                   | -                      |
| <a href="#">Non-Condensables</a>                      | *Add to Discharge Pressure Reduction |                     |                        |
| <a href="#">Optimize Defrost</a>                      |                                      |                     |                        |
| <b>Total Refrigeration Energy Savings Opportunity</b> | <b>2,169,718</b>                     | <b>\$149,857.70</b> |                        |

22

23

24

25

26

27

28

29

30

**Compressors Condensers Evaporators**

| Component   | Percentage |
|-------------|------------|
| Compressors | 81%        |
| Condensers  | 11%        |
| Evaporators | 8%         |

Summary Compressors Condensers Evaporators Discharge Pressure Increase Suction Temp Compressor Sequencing Superheat Non-Condensab ...


# Performance Tracking

|       | Total Electric Spend | kWh | Calculated    |       | Total       |       | Progress - thru | Progress - thru   | Progress - thru  |
|-------|----------------------|-----|---------------|-------|-------------|-------|-----------------|-------------------|------------------|
|       |                      |     | Refrigeration | % of  | Reduction   | % of  | Feb (% Savings) | Feb (kWh Savings) | Feb (\$ Savings) |
|       |                      |     | Energy Cost   | Total | Opportunity | Total |                 |                   |                  |
| TYSON |                      |     |               | 26.8% |             | 2.9%  |                 |                   | 3.2%             |
|       |                      |     |               | 2.8%  |             | 0.6%  |                 |                   | 0.7%             |
|       |                      |     |               | 8.7%  |             | 4.1%  |                 |                   |                  |
|       |                      |     |               | 54.8% |             | 1.1%  |                 |                   | 0.7%             |
|       |                      |     |               | 61.6% |             | 1.6%  |                 |                   | 7.4%             |
|       |                      |     |               |       |             | -     |                 |                   | 7.0%             |
|       |                      |     |               | 60.3% |             | 11.0% |                 |                   | 4.0%             |
|       |                      |     |               | 37.2% |             | 0.6%  |                 |                   | 10.3%            |
|       |                      |     |               | 59.1% |             | 1.3%  |                 |                   | 6.2%             |
|       |                      |     |               |       |             | -     |                 |                   | 7.6%             |
|       |                      |     |               | 43.1% |             | 9.0%  |                 |                   | 0.0%             |
|       |                      |     |               | 63.3% |             | 0.3%  |                 |                   | 9.8%             |
|       |                      |     |               |       |             | -     |                 |                   | 2.2%             |
|       |                      |     |               | 61.9% |             | 4.6%  |                 |                   | 5.4%             |
|       |                      |     |               | 62.5% |             | 6.1%  |                 |                   | 1.1%             |
|       |                      |     |               | 54.0% |             | 4.8%  |                 |                   | -8.8%            |
|       |                      |     |               | 51.6% |             | 9.9%  |                 |                   | 6.7%             |
|       |                      |     |               | 47.3% |             | 1.7%  |                 |                   | -6.3%            |
|       |                      |     |               |       |             | -     |                 |                   | 0.4%             |
|       |                      |     |               | 59.2% |             | 1.3%  |                 |                   | 8.8%             |
|       |                      |     |               |       |             | -     |                 |                   | 7.6%             |
|       |                      |     |               |       |             | -     |                 |                   | -8.5%            |
|       |                      |     |               |       |             | -     |                 |                   | -14.9%           |
|       |                      |     |               | 37.3% |             | 1.9%  |                 |                   | 2.9%             |

These are total energy savings from the project and due to inability to isolate data, we cannot confirm 100% of the savings comes from refrigeration systems.



# Results from Oct 2020 to Feb 2021



Energy Savings in first 5 months: 73,267,160 kWh (4.8%)

\* Texas plants did not contain February billing.

\*\* New plants, acquisition plants, and expansion plants not reflected in this data.

These are total energy savings from the project and due to inability to isolate data, we cannot confirm 100% of the savings comes from refrigeration systems.

Questions / Comments

---

**To submit questions, please go to**

**[www.slido.com](http://www.slido.com)**

**using your mobile device, or by opening a new window**

**Enter Event Code**

**#DOE**

---

# Q & A

Submit Questions  
[www.slido.com](https://www.slido.com) event code **#DOE**

# Better Buildings: Summer Webinar Series



## ELECTRIFYING OUR BUILDINGS: CHALLENGES AND SOLUTIONS

June 8



## BECOMING ESPC-READY

June 15



## BOOSTING INDUSTRIAL AND MANUFACTURING EFFICIENCY AND RESILIENCY WITH CHP

June 17



## FINANCING IN HIGHER EDUCATION

June 22



## WHAT'S HOT WITH HEAT PUMPS

June 29



## HOW TO IDENTIFY CHP PROJECTS THAT FIT YOUR GOALS

July 1



## KICK THE TIRES: UNDERSTANDING THE ROLE OF R&D IN THE DEPLOYMENT OF BUILDING ENERGY TECHNOLOGIES

July 6




## ESPC IN THE EXPRESS LANE: NEW PROJECT TRACKING TOOLS

July 13



## WORKPLACE EVOLUTION: SUPPORTING OCCUPANT HEALTH WHILE ACHIEVING ENERGY EFFICIENCY

July 20



## ENERGY-SAVING ENVELOPE SUCCESS STORIES

July 27



## WASTE REDUCTION: LESSONS LEARNED AND WHAT COMES NEXT

August 3



## VISUALIZE YOUR ENERGY FUTURE WITH 'SLOPE': THE STATE AND LOCAL PLANNING FOR ENERGY PLATFORM

August 10

# Additional Questions?

## Please Contact Us



Follow us on Twitter  
[@BetterPlantsDOE](#)  
[@BetterBldgsDOE](#)



Better Buildings Solution Center  
<https://betterbuildingsolutioncenter.energy.gov/>



General Inquiries  
[BetterPlants@ee.doe.gov](mailto:BetterPlants@ee.doe.gov)



Program Support  
[Clifton.Yin@ee.doe.gov](mailto:Clifton.Yin@ee.doe.gov)

3M – Prasath Vinayagamoorthy & Brian Mohr  
[pvinayagamoorthy@mmm.com](mailto:pvinayagamoorthy@mmm.com)  
[bmohr@mmm.com](mailto:bmohr@mmm.com)

Flowers Foods – Margaret Ann Marsh  
[MargaretAnn.Marsh@flocorp.com](mailto:MargaretAnn.Marsh@flocorp.com)

Graham Packaging – Balaji Jayaseelan  
[balaji.jayaseelan@grahampackaging.com](mailto:balaji.jayaseelan@grahampackaging.com)

Lockheed Martin – Michael Stein  
[michael.2.stein@lmco.com](mailto:michael.2.stein@lmco.com)

Nissan North America – Brett Rasmussen  
[brett.rasmussen@nissan-usa.com](mailto:brett.rasmussen@nissan-usa.com)

Owens Corning – Don Scarsella  
[Don.Scarsella@owenscorning.com](mailto:Don.Scarsella@owenscorning.com)

SugarCreek Packing Co. – Todd Jackson  
[tjackson@sugar-creek.com](mailto:tjackson@sugar-creek.com)

Tyson Foods – Alex Floyd  
[Alex.Floyd@tyson.com](mailto:Alex.Floyd@tyson.com)