

CHENANGO VALLEY CENTRAL SCHOOL DISTRICT
2020 LEAD IN DRINKING WATER TEST RESULTS

Port Dickinson Elementary 770 Chenango St. Binghamton NY 13901		
SAMPLE	1st Draw (ppb)	Notes
PD-HS-1	<1	Kitchen hand washing sink
PD-HS-2	<1	Kitchen hand washing sink
PD-HS-3	2.1	Kitchen hand washing sink
PD-PS-1	<1	Kitchen Prep Sink
PD-PS-2	<1	Kitchen Prep Sink
PD-DS-1	<1	Kitchen dishwashing sink
PD-DS-2	<1	Kitchen dishwashing sink
101B FIRST DRAW BUBBLER	1.5	Classroom 101 Bubbler
101S FIRST DRAW SINK	1.6	Classroom 101 Sink
102B FIRST DRAW BUBBLER	<1	Classroom 102 Bubbler
102S FIRST DRAW SINK	1.4	Classroom 102 Sink
103B FIRST DRAW BUBBLER	<1	Classroom 103 Bubbler
103S FIRST DRAW SINK	2.9	Classroom 103 Sink
104B FIRST DRAW BUBBLER	<1	Classroom 104 Bubbler
104S FIRST DRAW SINK	1.8	Classroom 104 Sink
1ST DF BF FIRST DRAW DRINKING FOUNTAIN	1	1st Floor Corridor Bottle Filler
1ST DF L FIRST DRAW DRINKING FOUNTAIN LEFT	<1	1st Floor Corridor Left Drinking Fountain
1ST DF R FIRST DRAW DRINKING FOUNTAIN RIGHT	<1	1st Floor Corridor Right Drinking Fountain
201B FIRST DRAW BUBBLER	<1	Classroom 201 Bubbler
201S FIRST DRAW SINK	4.3	Classroom 201 Right Sink
201SL FIRST DRAW SINK L	5	Classroom 201 Left Sink
202B FIRST DRAW BUBBLER	<1	Classroom 202 Bubbler
202S FIRST DRAW SINK	1.4	Classroom 202 Sink
203B FIRST DRAW BUBBLER	<1	Classroom 203 Bubbler
206B FIRST DRAW BUBBLER	<1	Classroom 206 Bubbler
203S FIRST DRAW SINK	1.8	Classroom 203 Sink
204B FIRST DRAW BUBBLER	<1	Classroom 204 Bubbler

CHENANGO VALLEY CENTRAL SCHOOL DISTRICT
2020 LEAD IN DRINKING WATER TEST RESULTS

204S FIRST DRAW SINK	2.9	Classroom 204 Sink
205B FIRST DRAW BUBBLER	1	Classroom 205 Bubbler
205S FIRST DRAW SINK	2.1	Classroom 205 Sink
206S FIRST DRAW SINK	1.4	Classroom 206 Sink
207B FIRST DRAW BUBBLER	1.3	Classroom 207 Bubbler
207S FIRST DRAW SINK	1.3	Classroom 207 Sink
208B FIRST DRAW BUBBLER	1	Classroom 208 Bubbler
208S FIRST DRAW SINK	1.3	Classroom 208 Sink
209B FIRST DRAW BUBBLER	<1	Classroom 209 Bubbler
209S FIRST DRAW SINK	1.7	Classroom 209 Sink
210B FIRST DRAW BUBBLER	<1	Classroom 210 Bubbler
210S FIRST DRAW SINK	1.6	Classroom 210 Sink
220S KITCHENETTE FIRST DRAW SINK	7.9	Faculty Lounge Kitchenette Sink
222B FIRST DRAW BUBBLER	<1	Classroom 222 Bubbler
222S FIRST DRAW SINK	<1	Classroom 222 Sink
301B FIRST DRAW BUBBLER	<1	Classroom 301 Bubbler
301S FIRST DRAW SINK	1.3	Classroom 301 Sink
302B FIRST DRAW BUBBLER	<1	Classroom 302 Bubbler
302S FIRST DRAW SINK	1	Classroom 302 Sink
303B FIRST DRAW BUBBLER	1	Classroom 303 Bubbler
303S FIRST DRAW SINK	1.5	Classroom 303 Sink
304B FIRST DRAW BUBBLER	<1	Classroom 304 Bubbler
304S FIRST DRAW SINK	<1	Classroom 304 Sink
305B FIRST DRAW BUBBLER	<1	Classroom 305 Bubbler
305S FIRST DRAW SINK	1.7	Classroom 305 Sink
306B FIRST DRAW BUBBLER	<1	Classroom 306 Bubbler

CHENANGO VALLEY CENTRAL SCHOOL DISTRICT
2020 LEAD IN DRINKING WATER TEST RESULTS

306S FIRST DRAW SINK	<1	Classroom 306 Sink
317S FIRST DRAW SINK	1.4	Classroom 317 Sink
3RD DF FIRST DRAW DRINKING FOUNTAIN	<1	3rd Floor Corridor Drinking fountain outside of Conference room
3RD DF @ COURTYARD FIRST DRAW DRINKING FOUNTAIN	<1	3rd Floor Corridor Drinking fountain outside of Room 305
401B FIRST DRAW BUBBLER	<1	Classroom 401 Bubbler
401S FIRST DRAW SINK	1.4	Classroom 401 Sink
402B FIRST DRAW BUBBLER	1	Classroom 402 Bubbler
402S FIRST DRAW SINK	2	Classroom 402 Sink
403B FIRST DRAW BUBBLER	1.4	Classroom 403 Bubbler
403S FIRST DRAW SINK	2.8	Classroom 403 Sink
404B FIRST DRAW BUBBLER	<1	Classroom 404 Bubbler
404S FIRST DRAW SINK	1.9	Classroom 404 Sink
405B FIRST DRAW BUBBLER	<1	Classroom 405 Bubbler
405S FIRST DRAW SINK	1.3	Classroom 405 Sink
408B FIRST DRAW BUBBLER	1.7	Classroom 408 Bubbler
408S FIRST DRAW SINK	1.4	Classroom 408 Sink
409B FIRST DRAW BUBBLER	<1	Classroom 409 Bubbler
409S FIRST DRAW SINK	1.1	Classroom 409 Sink
410B FIRST DRAW BUBBLER	<1	Classroom 410 Bubbler
410S FIRST DRAW SINK	3	Classroom 410 Sink
411B FIRST DRAW BUBBLER	<1	Classroom 411 Bubbler
411S FIRST DRAW SINK	1.1	Classroom 411 Sink
412B FIRST DRAW BUBBLER	<1	Classroom 412 Bubbler
412S FIRST DRAW SINK	1.1	Classroom 412 Sink
413B FIRST DRAW BUBBLER	<1	Classroom 413 Bubbler

CHENANGO VALLEY CENTRAL SCHOOL DISTRICT
2020 LEAD IN DRINKING WATER TEST RESULTS

413S FIRST DRAW SINK	1.7	Classroom 413 Sink
4TH DF FIRST DRAW DRINKING FOUNTAIN	2.1	4th Floor Corridor Drinking Fountain
LIBRARY CONF S FIRST DRAW SINK	2.9	Library Conference room (room 311) Sink
OT/PT B FIRST DRAW BUBBLER	<1	Classroom 221 (OT/PT) Bubbler
OT/PT S FIRST DRAW SINK	1.3	Classroom 221 (OT/PT) Sink
Chenango Bridge Elementary School 741 River Road, Binghamton NY 13901		
SAMPLE	1st Draw	Notes
CB-HS-1	3.3	Kitchen Hand sink 1
CB-HS-2	14.3	Kitchen Hand sink 2
CB-PS-1	<1	Kitchen Prep sink 1
CB-DS-1	<1	Kitchen Dish sink 1
CB-DS-2	<1	Kitchen Dish sink 2
CB-PS-2	1.1	Kitchen Prep sink 2
101 FIRST DRAW S Faucet, Cold 101	1.2	Classroom 100 Sink
104 FIRST DRAW S Faucet, Cold 104	1.4	Classroom 104 Sink
1-2DF FIRST DRAW DF Drinking Fountain 1-2	<1	1st Floor Corridor Drinking fountain near Main office
1-2BF FIRST DRAW BF Bottle Filler 1-2	<1	1st Floor Corridor Bottle Filler near Main office
114 FIRST DRAW S Faucet, Cold 141	1	Nurse Office Sink
114A FIRST DRAW S Faucet, Cold 141A	3.4	Nurse Office Restroom Sink
114C FIRST DRAW S Faucet, Cold 141C	1.2	Nurse Office Exam Room Sink
111S FIRST DRAW S Faucet, Cold 103	6.2	Classroom 111 (Ot/PT room) Sink
111B FIRST DRAW B Bubbler 103	1.3	Classroom 111 (Ot/PT room) Bubbler
113S FIRST DRAW S Faucet, Cold 105	11.7	Classroom 113 Sink
115SA FIRST DRAW S Faucet, Cold 107	4.7	Classroom 115 Left Sink
115SB FIRST DRAW S Faucet, Cold 107	3.7	Classroom 115 Right Sink
115B FIRST DRAW B Bubbler 107	2.3	Classroom 115 Bubbler
128S FIRST DRAW S Faucet, Cold 116	3.3	Classroom 128 Sink
128B FIRST DRAW B Bubbler 116	1.8	Classroom 128 Bubbler
130S FIRST DRAW S Faucet, Cold 120	<1	Classroom 130 Sink

CHENANGO VALLEY CENTRAL SCHOOL DISTRICT
2020 LEAD IN DRINKING WATER TEST RESULTS

130B FIRST DRAW B Bubbler 120	1.4	Classroom 130 Bubbler
132S FIRST DRAW S Faucet, Cold 124	1.4	Classroom 123 Sink
132B FIRST DRAW B Bubbler 124	1.3	Classroom 123 Bubbler
125S FIRST DRAW S Faucet, Cold 122	2.1	Classroom 125 Sink
125B FIRST DRAW B Bubbler 122	1.8	Classroom 125 Bubbler
134S FIRST DRAW S Faucet, Cold 128	1.2	Classroom 134 Sink
134B FIRST DRAW B Bubbler 128	1.8	Classroom 134 Bubbler
127S FIRST DRAW S Faucet, Cold 126	4.4	Classroom 127 Sink
127B FIRST DRAW B Bubbler 126	2.8	Classroom 127 Bubbler
136S FIRST DRAW S Faucet, Cold 132	1.3	Classroom 136 Sink
136B FIRST DRAW B Bubbler 132	<1	Classroom 136 Bubbler
129S FIRST DRAW S Faucet, Cold 130	1.9	Classroom 129 Sink
129B FIRST DRAW B Bubbler 130	2.1	Classroom 129 Bubbler
123A FIRST DRAW S Faucet, Cold 123A	2.8	Classroom 123 Sink
1-5DF FIRST DRAW DF Drinking Fountain 1- 5	<1	1st Floor Corridor Drinking fountain Near Gym
1-5BF FIRST DRAW BF Bottle Filler 1-5	<1	1st Floor Corridor Bottle filler Near Gym
131S FIRST DRAW S Faucet, Cold 109	5.3	Classroom 131 Sink
131B FIRST DRAW B Bubbler 109	3.1	Classroom 131 Bubbler
133S FIRST DRAW S Faucet, Cold 111	2.8	Classroom 133 Sink
133B FIRST DRAW B Bubbler 111	4	Classroom 133 Bubbler
135S FIRST DRAW S Faucet, Cold 113	<1	Classroom 135 Sink
135B FIRST DRAW B Bubbler 113	<1	Classroom 135 Bubbler
137S FIRST DRAW S Faucet, Cold 115	1.1	Classroom 137 Sink
137B FIRST DRAW B Bubbler 115	1.5	Classroom 137 Bubbler
139S FIRST DRAW S Faucet, Cold 117	<1	Classroom 139 Sink
139B FIRST DRAW B Bubbler 117	1.5	Classroom 139 Bubbler

CHENANGO VALLEY CENTRAL SCHOOL DISTRICT
2020 LEAD IN DRINKING WATER TEST RESULTS

141S FIRST DRAW S Faucet, Cold 119	<1	Classroom 141 Sink
141B FIRST DRAW B Bubbler 119	1.7	Classroom 141 Bubbler
143S FIRST DRAW S Faucet, Cold 121	1.3	Classroom 143 Sink
143B FIRST DRAW B Bubbler 121	1.4	Classroom 143 Bubbler
211S FIRST DRAW S Faucet, Cold 209	1.1	Classroom 211 Sink
212B FIRST DRAW B Bubbler 208	1.4	Classroom 212 Bubbler
209S FIRST DRAW S Faucet, Cold 207	1.5	Classroom 209 Sink
209B FIRST DRAW B Bubbler 207	1	Classroom 209 Bubbler
210S FIRST DRAW S Faucet, Cold 206	1.6	Classroom 210 Sink
207S FIRST DRAW S Faucet, Cold 205	2.5	Classroom 207 Sink
208S FIRST DRAW S Faucet, Cold 204	1.7	Classroom 208 Sink
2-1DF FIRST DRAW DF Drinking Fountain 2- 1	<1	2nd Floor Corridor Drinking fountain Near Elevator
2-1BF FIRST DRAW BF Bottle Filler 2-1	<1	2nd Floor Corridor Bottle filler Near Elevator
Chenango Valley Middle/High School 221 Chenango Bridge Road, Binghamton NY, 13901		
SAMPLE	1st Draw	Notes
CV-1	<1	Kitchen prep sink
CV-2	<1	Kettle in Kitchen
CV-3	1.4	Kitchen sprayer adj to prep sink
CV-4	<1	Ice machine - Kitchen
CV-5	<1	District office Kitchenette sink
CV-6	<1	WF across from RM 119
CV-7	<1	WF adj to girls room
CV-8	<1	BF adj to girls room
CV-9	<1	Sink near window RM 126
CV-10	<1	Sink adj to window sink RM 126
CV-11	1.2	Sink near wall RM 126
CV-12	1.2	Middle sink RM126
CV-13	<1	Sink adj to cupboard RM 126
CV-14	<1	MS gym boys Water fountain
CV-15	<1	MS gym girls Water Fountain
CV-16	<1	RM 128 sink
CV-17	<1	RM 131 sink 1
CV-18	<1	RM 131 sink 2
CV-19	<1	RM 131 sink 3
CV-20	<1	RM 131 sink 4
CV-21	<1	Water Fountain near wrestling room
CV-22	<1	Staff dining sink
CV-23	3.4	Nurse sink 1

CHENANGO VALLEY CENTRAL SCHOOL DISTRICT
2020 LEAD IN DRINKING WATER TEST RESULTS

CV-24	2.8	Nurse sink 2
CV-25	1.3	Nurse sink 3
CV-26	<1	Library prep sink (RM D)
CV-27	<1	WF across from RM 106
CV-28	<1	WF adj to RM 104
CV-29	<1	WF across from auditorium
CV-30	<1	BF across from auditorium
CV-31	<1	WF adj to RM 164 (left)
CV-32	<1	WF adj to RM 164 (right)
CV-33	<1	WF HS girls locker RM
CV-34	<1	WF HS boys locker RM
CV-35	<1	BF across from HS gym
CV-36	<1	WF 1 across from HS gym
CV-37	<1	WF 2 across from HS gym
CV-38	2	Concession stand sink
CV-39	Not in service at time of sampling.	WF girls pool locker RM
CV-40	Not in service at time of sampling.	BF girls pool locker RM
CV-41	<1	BF boys pool locker RM
CV-42	<1	WF boys pool locker RM
CV-43	1.6	RM 144 Ice machine
CV-43A	<1	RM 144 sink
CV-44	<1	WF across from fitness RM
CV-45	<1	BF across from fitness RM
CV-46	<1	RM 146 sink
CV-47	Not in service at time of sampling.	WF near mechanical RM
CV-48	Not in service at time of sampling.	BF near mechanical RM
CV-49	3.8	RM 246 prepsink
CV-50	<1	RM 248 prepsink
CV-51	3.2	RM 252 prepsink
CV-52	<1	WF1 across from store room
CV-53	<1	WF2 across from store room
CV-54	1.5	RM 260 prepsink
CV-55	9.9	RM 263 prepsink
CV-56	<1	WF across from RM 241
CV-57	<1	RM 236 prepsink
CV-58	<1	RM 234 prepsink
CV-59	<1	RM 231 prepsink
CV-60	<1	WF across from RM 228
CV-61	<1	RM 216 prepsink
CV-62	<1	WF across from RM 216
CV-63	<1	WF across from RM 211
CV-64	<1	WF adj to girls room by guidance office
CV-65	Not in service at time of sampling.	Hose bib field house
CV-66	Not in service at time of sampling.	Hose bib field house 2