UL 2727

Outline of Investigation for Retrofit Motor Control Center Units For Use With Specified Motor Control Center Sections

Edition Number: 1 SCC Approved: -Edition Date: 2010-02-15 DOD Approved: -Price Code: A NSI Approved: -Type: outline

SCOPE

1 Scope

1.1 These requirements cover motor control center units intended for use as retrofits for use with specified motor control centers rated 600 V maximum where the available short-circuit current is 200 kA maximum.