

OR

DENOTES TERMINAL BLOCK

SUPER SYSTEMS INC.
(800) 666-4330
www.supersystems.com

- 1 - 24VDC (COM)
- 2 - 24VDC (+)
- 3 - RS485 RT (-)
- 4 - RS485 RT (+)
- 5 - SLAVE 1, RS485 (+)
- 6 - SLAVE 1, RS485 (-)
- 7 - RELAY COMMON
- 8 - RELAY OUT 1
- 9 - RELAY OUT 2
- 10 - RELAY OUT 3
- 11 - RELAY OUT 4
- 12 - RELAY OUT 5
- 13 - RELAY OUT 6
- 14 - RELAY OUT 7
- 15 - RELAY OUT 8 NC
- 16 - RELAY OUT 8 NO
- 17 - DIGITAL IN 1
- 18 - ANALOG IN 3 (+)
- 19 - ANALOG IN 3 (-)
- 20 - ANALOG IN 4
- 21 - DIGITAL IN COM
- 22 - SLAVE 2, RS485 (+)
- 23 - SLAVE 2, RS485 (-)
- 24 - 4-20mA OUT 1 (+)
- 25 - 4-20mA OUT 2 (+)
- 26 - 4-20mA OUT 2 (-)
- 27 - ANALOG IN 2 (+)
- 28 - ANALOG IN 2 (-)
- 29 - ANALOG IN 1 (+)
- 30 - ANALOG IN 1 (-)
- 31 - ANALOG IN 1 (+)
- 32 - ANALOG IN 1 (-)

SERIES 9120 PINDOUT LABEL

COMBO ALARM

PROGRAM ALARM, ALARM 01,
ALARM 02, AND ALARM 03

REFERENCE DRAWING(S)
THIS DRAWING IS FURNISHED AS A
GUIDELINE ONLY.
FINAL INSTALLATION DIAGRAMS
ARE THE RESPONSIBILITY OF OTHERS.
CONFIDENTIAL

| | | | | |
|---|-------------|-------------|-------------|--------------------|
| REV. | DESCRIPTION | DRAWN | DATE | APPROVED |
| A | ECD - 00412 | | 24 MAR 2017 | |
| SERIES 9120 ATMOSPHERE CONTROL SYSTEM - RS-232 COMMUNICATIONS TO 12.1" DIT | | | | |
| BASIC WIRING DIAGRAM | | | | |
| APPROVALS | DATE | DWG. NO. | 13607 | REV. A |
| DRAWN | GDG | 26 MAR 2014 | | |
| CHECKED | CHKD | DATE | CHKD | VELECTRONICS\13607 |
| ISSUED | DATE | ISSUED | SCALE | 1:1 |
| SHEET 01 OF 02 | | | | |

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES
FRACTIONS DECIMALS
#1/64"
X.XX=±0.100 ±0.5"
X.XXX=±0.010 ±0.5"
X.XXX=±0.001

SSI
CINCINNATI, OHIO

139
1002 WHT

139
1001 RED

1002 WHT

1001 RED

