MORCLEAN

Is there a risk of oil contaminating drainage from your site. e.g. from wash water, spillages, car park run off, fuels, oils etc?

YES → Risk of light contamination & potential for spills only e.g. your car park

YES → A Bypass Separator with alarm is required

YES → Are you connecting to a surface water drain? → YES → A Class 1 Bypass Separator with alarm is required

YES → Are you connecting to a mains foul sewer? → YES → A Class 2 Bypass Separator with alarm is required

→ Morclean will require the area of the car park in M2 or cross reference on spec sheet BP1 → You are ready to place your order

YES → Is their a risk of regular contamination of surface water run off with oil and/or risk of larger spills e.g. vehicle maintenance area, goods vehicle parking or vehicle manoeuvering?

YES → Are you connecting to a surface water drain? → YES → A Class 1 Full Retention Separator with alarm is required

YES → Are you connecting to a mains foul sewer? → YES → A Class 2 Full Retention Separator with alarm is required

→ Morclean will require the area of the car park in m2 or cross reference on spec sheet FR1 → You are ready to place your order

YES → Very low risk of oil contamination e.g. roof water run off

YES → Separator not required → Clean water should not be passed through a separator unless the size of the unit is increased accordingly

YES → Drainage of trade effluents e.g. industrial sites

YES → Trade effluents must be directed to the foul sewer. It may need to pass through a separator before discharge to sewer.

YES → Outflow of dissolved oils, use of detergents, degreasers such as a vehicle wash area

YES → A wash bay should be constructed. It should be isolated & surrounded by a kerb. Wash water should be contained & directed to a silt trap.

→ Do you have a mains foul sewer available?

YES → Water outflows to a 3 Stage Vehicle Wash Full Retention interceptor → Morclean will require the number of washes, frequency of use, type of wash facility e.g. hot or cold, jetwash, drive through wash, gantry wash etc → Outflow of wash water must be directed to mains foul sewer

NO → There is only a surface water drain available → The effluent must **not** be directed to a surface drain

→ Water can be contained in a sealed drainage system & disposed of by a licensed waste carrier.

→ Water can be recycled using a Morclean Recycle Unit via a 3 Stage Interceptor.

Tel: 01246 471147 Fax: 01246 471277 Web: www.morclean.co.uk